ALABAMA STATE COMMITTEE OF PUBLIC HEALTH
ALABAMA DEPARTMENT OF PUBLIC HEALTH
BUREAU OF ENVIRONMENTAL SERVICES
DIVISION OF COMMUNITY ENVIRONMENTAL PROTECTION
ADMINISTRATIVE CODE

CHAPTER 420-3-1
ONSITE SEWAGE TREATMENT AND DISPOSAL

420-3-1-.26 Advanced Treatment System (ATS) Specifications.

(1) A person proposing to market a proprietary advanced treatment system (ATS) shall submit ADPH Form CEP-13. The application shall include the following information:

(a) Documentation that the ATS has been certified as meeting the appropriate NSF, Committee for Standardization (CEN), or the Bureau de normalisation du Quebec (BNQ) Standard.

(b) Design hydraulic loading capacity (gallons per day) and design organic loading capacity (pounds of BOD per day).

(2) An ATS shall comply with the following requirements:

(a) The conditions of a Performance Permit or be currently listed and certified by a testing organization as meeting the appropriate NSF. CEN, or BNQ standard.

(b) Be capable of producing effluent that meets secondary effluent standards as defined by these rules.

Author: Thad Pittman, Matthew Conner, Ken Stephens, Bob Bright
Statutory Authority: Code of Ala. 1975, §§22-2-2(4); 22-2-2(6); 22-10-1, et seq.; 22-26-1, et seq.
History: **New Rule:** Filed October 20, 2005; effective November 24, 2005; operative March 19, 2006. **Amended:** Filed October 19, 2006; effective November 23, 2006. **Repealed and New Rule:** Filed January 19, 2017; effective March 5, 2017. **Repealed and New Rule:** Published December 30, 2022; effective February 13, 2023.

Ed. Note: Previous Rule .37 was renumbered .26 per certification published December 30, 2022; effective February 13, 2023.